



**Community Development  
Building Division**

**REQUEST FOR MEDIUM PRESSURE  
GAS SERVICE**

**Project Name:** \_\_\_\_\_

**Address:** \_\_\_\_\_

**Owner:** \_\_\_\_\_

Medium pressure gas installations are regulated by Chapter 13 of the California Mechanical Code, and by Chapter 12 of the California Plumbing Code.

Concealing of medium pressure gas piping shall be avoided, but if approved, joints shall be welded. The necessary regulators shall be readily accessible, with permanent ladders, catwalks, working platforms and lights as required, for inspection and servicing.

Exposed piping and piping on the roof may be screwed pipe. Regulators on the roof shall be accessible by means of a permanent ladder, as designed for other roof mounted equipment.

Gas Cocks shall be approved for the pressure supplied.

Medium pressure gas lines shall be tested at sixty (60) psi, for twenty-four (24) hours.

Submit three (3) isometric drawings of the gas piping indicating location of the piping, appliances, regulators including relief piping and gas meter in relation to the building walls and lot line, to the City of Folsom, Building Division.

**Mechanical Engineer/ Contractor:** \_\_\_\_\_

**Address:** \_\_\_\_\_ **License No.:** \_\_\_\_\_

\_\_\_\_\_ **Phone:** \_\_\_\_\_

The request for medium pressure gas service at the above address has been approved by both the City of Folsom, Building Division and PG&E.

The requested demand is \_\_\_\_\_ BTU's per hour.

The pressure requested is \_\_\_\_\_ psi.

\_\_\_\_\_  
(PG&E Representative) Date: \_\_\_\_\_

Approved for service: \_\_\_\_\_ Date: \_\_\_\_\_  
Folsom Chief Building Official