



CITY OF
FOLSOM
DISTINCTIVE BY NATURE

2012 Consumer Confidence Report May 2013

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien. (This report contains important information about your drinking water. Translate it, or speak with someone who understands it.)

HIGH QUALITY DRINKING WATER IS FOLSOM'S PRIMARY CONCERN

The City of Folsom is committed to providing our customers with high quality drinking water. Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (USEPA) and State drinking water health standards. The City of Folsom takes every effort to safeguard its water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

The California Department of Public Health (Department) requires that state certified water treatment operators and distribution operators monitor and sample your drinking water from source to tap on an hourly, daily, monthly, quarterly, and annual basis using state-of-the-art equipment and state-certified labs.

ABOUT THE CONSUMER CONFIDENCE REPORT

The Consumer Confidence Report (CCR) is an annual summary of the results of ongoing tests for contaminants in drinking water. The report is designed to inform you of the quality of your drinking water. Each year, the Department and USEPA require the City of Folsom to compile and distribute a CCR to all of our water customers. The report includes a comparison of the city's water quality to state and federal standards.

WHERE YOUR WATER COMES FROM

The City of Folsom receives all of its drinking water from Folsom Lake. Water drawn from the lake is piped to the Folsom Water Treatment Plant where it undergoes several treatment processes before it is delivered to our customers.

YOUR DRINKING WATER – WHAT YOU SHOULD KNOW

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Contaminants that may be present in source water include:

- *Microbial contaminants such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;*

- *Inorganic contaminants such as salts and metals that can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming;*

- *Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.*

- *Organic chemical contaminants including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, or from gas stations, urban storm water runoff, and septic systems; and*

- *Radioactive contaminants, that can be naturally occurring or be the result of oil and gas production and mining activities.*

In order to ensure that tap water is safe to drink, USEPA and the Department prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

The City of Folsom conducted lead and copper sampling in July 2011 and found the water supply did not exceed any mandated standards. Copper or lead contamination may occur from the internal corrosion of household plumbing systems or the erosion of natural deposits. Copper contamination may also occur from the leaching from wood preservatives, and lead contamination may also occur from discharges from industrial manufacturers.

Adverse health effects are possible with excess consumption of many water constituents, including lead and copper. Copper may cause gastrointestinal distress or kidney or liver failure with long-term excess exposure. Long-term excess exposure to lead may cause developmental delays in children and kidney problems or high blood pressure in adults.

INFORMATION ABOUT POTENTIAL SOURCES OF POLLUTION

The Department requires water providers to conduct a source water assessment to help protect the quality of future water supplies. The assessment describes where a water system's drinking water comes from, the types of polluting activities that may threaten source water quality and an evaluation of the water's vulnerability to those threats.

A source water assessment was conducted for the City of Folsom's water supply from Folsom Lake in March 2002. The assessment concluded that the City of Folsom's water source is considered most vulnerable to the following activities associated with contaminants detected in the water supply: Folsom Lake State Recreation Area facilities (marina, restrooms, recreational areas, parking lots, and storm drains) and residential sewer and septic systems. The assessment also concluded that source is most vulnerable to the following activities not associated with any detected contaminants: illegal activities, dumping, fertilizer, pesticide and herbicide application, and high-density housing developments.

A copy of the complete assessment is available at the California Department of Public Health, Sacramento District Office, 1616 Capitol Avenue, Sacramento, CA. You may request a summary of the assessment be sent to you by contacting Richard Hinrichs, Northern California Region 1 Engineer, at (916) 449-5600 or Todd Eising, Environmental and Water Resources Section Manager, at (916) 351-3502.

IMPORTANT NOTICE FOR SENSITIVE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

READING THE WATER QUALITY DATA

1. Identify constituents in the left hand column.
2. Compare detection range to the state (MCL/PHG) standards.
3. Confirm that your water meets state drinking water health standards.

WATER QUALITY DEFINITIONS

The following definitions are listed to help you understand the information recorded in the water quality chart:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detected (ND): Not detected at or above the reporting limit.

HAVE QUESTIONS?

For a complete list of constituents tested or to request additional copies of the Consumer Confidence Report, please contact the Water Quality Division at (916) 355-8338 or email waterquality@folsom.ca.us. The Consumer Confidence Report is also available at our website at www.folsom.ca.us.

NEED CONSERVATION TIPS?

For water conservation tips and free supplies, please contact the Conservation Coordinator at (916) 355-7252 or visit our website at www.folsom.ca.us.

GET INVOLVED

The Folsom City Council meetings are open to the public and are held on the 2nd and 4th Tuesdays of each month at 6:30 p.m. Meetings are located at City Hall, 50 Natoma Street. Meetings are also broadcast on Metro Cable Channel 14 at 9:00 a.m. on Friday and Saturday of meeting weeks.

The information provided in this water quality chart is required by law to be issued to every water user. Property Owners – Please share this information with your tenants!

City of Folsom 2012 Water Quality Report

Contaminant	Units	MCL	PHG	Ashland				Folsom				Major Sources in Drinking Water	
				Range		Average	Exceeds MCL?	Range		Average	Exceeds MCL?		
				Min	Max			Min	Max				
% Coliform Present		5% ^(a)	(0)									No	Naturally present in the environment
Alkalinity	ppm			22	26	24		16	29	24			
Bicarbonate	ppm			22	26	24		16	29	24			
Calcium	ppm			7.0	10	8.1		5.1	6.0	5.4			
Chloride	ppm	500*		2.5	3.2	2.8		1.8	9.9	7.2			Runoff/leaching from natural deposits; seawater influence
Chlorine	ppm	4 ^(b)		0.5	0.7	0.6		0.8	1.3	1.0			Drinking water disinfectant added for treatment
Haloacetic Acids ^(c)	ppb	60	n/a	22	42	32 (33)	No	16	52	32 (33)	No		By-product of drinking water chlorination
Hardness	ppm			23	37	28		18	24	21			
Magnesium	ppm			1.4	2.7	1.9		1.4	2.2	1.7			
Manganese	ppb	50*						ND	ND	ND		No	
Std													
pH	Units			7.7	8.1	7.9		6.8	8.0	7.4			
Sodium	ppm			2.1	2.9	2.4		2.2	7.4	6.2			
Specific Conductance	mS/cm	1600*		59	77	68		52	85	73			
Sulfate	ppm	500*		3.2	5.4	4.3		1.4	11	3.2			Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids	ppm	1000*		42	50	46		34	55	47			Runoff/leaching from natural deposits
Total Organic Carbon (effluent)	TT		n/a					0.82	1.3	0.78			Various natural and man-made sources
Total Trihalomethanes ^(c)	ppb	80	n/a	29	67	48 (44)	No	18	80	38 (37)	No		By-product of drinking water chlorination
Turbidity	TT		n/a					0.02	0.08	100% ^(d)			Soil runoff

* Secondary Maximum Contaminant Level
 (a) Percentage of coliform samples reported as "present" for coliform per month
 (b) MRDL
 (c) Locational running annual average of monitoring sites given in parentheses
 (d) Percentage of monthly total of combined filter effluent samples less than 0.3 NTU

The City of Folsom purchases water for the Ashland water system from San Juan Water District. Ashland is bounded on the north by the Placer County line, on the west by Baldwin Dam Road, and by the American River on the south and east.